

# Inspection

- Monthly inspection of Control and Indicating equipment.
- Six monthly inspection of:
  - Warden Intercom Points
  - Battery enclosures

# Tests

- AS 1851 now requires that all functions and indicators be tested annually including:
  - Call from each WIP
  - Call to each WIP
  - Simulate WIP fault
  - Warden present indicators
  - Visual indicators
  - Aural indicators

# Maintenance & Survey

Item No	Item	Action required & Pass/fail requirement	Frequency			Records		
			Monthly	Six-monthly	Yearly	Result	Pass/fail	Comments
3.1	Battery	REPLACE any battery older than two years unless it satisfactorily passes a battery capacity test.	✓	✓	✓	—	.....	
4.1	Change of structure	INSPECT building to that no structural changes have occurred to change zones.			✓	—	.....	
4.2	Change of occupancy	INSPECT the building to ensure that no changes to occupancy have effected the audibility of the warden call signal at the WIP			✓	—	.....	